

DEPARTMENT OF FISCAL SERVICES

PURCHASING DIVISION



September 19, 2003

To: PROSPECTIVE PROPOSERS AND ALL OTHERS CONCERNED

From: Tammy L. Cummings, CPPB, Contracts Analyst

Subject: CC-1218-03/TLC - Greenwood Lakes/Heathrow Interconnection Facilities

Due Date: October 22, 2003 @ 2:00 PM

ADDENDUM #1

Total pages: 3

The information included in this Addendum revises, clarifies, or supplements the specifications and other provisions of the contract documents and is considered part and parcel to the RFP Package.

The Greenwood Lakes/Heathrow Interconnection Facilities on-site work shall include the replacement of existing valves per the attached two sheets. Price for additional work shall be hand written as an add-on line item before the total cumulative price. All direct, indirect, incidental costs and labor cost shall be inclusive in the final bid price.


Failure to acknowledge receipt of this addendum on the submittal SHALL result in disqualification of your bid response.

Signature on File

Peter W. Maley, C.P.M., CPCM
Contracts Supervisor

GENERAL NOTES

1. NEW ELECTRICAL CONDUIT AND POWER WIRING TO BE INSTALLED FROM EXISTING RECLAIMED PUMP BUILDING WCC TO ELECTRIC VALVE MOTOR. POWER WIRING TO BE CORRECTLY SIZED FOR OPERATING THE VALVE MOTOR. ALL POWER WIRING SHALL BE PROVIDED PER THE VALVE MOTOR MANUFACTURER RECOMMENDATIONS.
2. EXISTING CONTROL WIRING AND CONTROL PANEL/RTU SHALL BE USED WITH THE NEW VALVES, OR UPGRADED PER THE REQUIREMENTS OF THE NEW VALVES.
3. OPERATION OF THE NEW VALVES SHALL REMAIN UNCHANGED FROM THE EXISTING OPERATING MODE, WHICH IS AS FOLLOWS: WHEN THE VALVE TO THE ON-SITE PONDS IS OPEN, THE VALVE TO THE GROUND STORAGE TANK SHALL BE CLOSED. CONVERSELY, WHEN THE VALVE TO THE ON-SITE PONDS IS CLOSED, THE VALVE TO THE GROUND STORAGE TANK SHALL BE OPEN. IN ADDITION, WATER LEVEL IN THE EXISTING GROUND STORAGE TANK SHALL CONTROL VALVE POSITION CONSISTANT WITH CURRENT OPERATION.
4. DIMENSIONS OF THE CONCRETE SLAB SHALL BE ADJUSTED AS REQUIRED TO ACCOMMODATE THE ACTUAL PIPE AND FITTINGS USED.
5. ALL DISTURBED AREAS SHALL BE RESTORED USING ARGENTINE-BAHIA SOO.
6. ALL REQUIRED ELECTRONIC CONTROLS AND INSTRUMENTS TO BE LOCATED AT THE VALVE STATION SHALL BE INSTALLED WITHIN A NEMA 4X STAINLESS STEEL PANEL. PANEL SHALL EITHER BE PAD MOUNTED, OR, MOUNTED ON A RACK PER THE DETAILS IN THE DRAWINGS.
7. 24" BUTTERFLY VALVES SHALL BE PRATT FLANGED BUTTERFLY VALVE ASSEMBLIES WITH LINKAGE AND MOTOR 480V/3 PHASE/60 HERTZ ELECTRIC MOTOR OPERATION FOR ON/OFF SERVICE, OR EQUAL.
8. THE REQUIRED ELECTRIC MOTOR SHALL BE MOUNTED ON BFF M.
9. THE OPERATOR FOR BFF #2 SHALL BE INTERCONNECTED TO BFF #1 USING STEEL LINKAGE.
10. SEE DRAWINGS FOR DETAILS REGARDING CONCRETE PIPE SUPPORTS.
11. SEE DRAWINGS AND SPECIFICATIONS REGARDING ELECTRICAL DETAILS.
12. SEE DRAWINGS AND SPECIFICATIONS REGARDING CONCRETE SLAB CONSTRUCTION REQUIREMENTS.
13. ALL ABOVE GROUND PIPING AND EQUIPMENT SHALL BE PAINTED PER THE REQUIREMENTS OUTLINED IN THE SPECIFICATIONS.
14. ALL BURIED FITTINGS AND PIPING SHALL BE INSTALLED USING MECHANICAL RESTRAINED JOINTS.
15. ALL PIPE AND FITTINGS TO BE PRESSURE TESTED PER THE REQUIREMENTS OF THE SPECIFICATIONS.
16. THE WORK SHOWN ON THIS SHEET SHALL NOT BE PERFORMED UNTIL AFTER THE NEW RECLAIMED WATER GROUND STORAGE TANK IS CONSTRUCTED AND OPERATIONAL.



REVISIONS			DATE	BY	DESCRIPTION	DESIGNED	CHECKED	IN CHARGE	PROJECT NO.	SHEET NO.	1





SEAWATER COUNTY
ENVIRONMENTAL SERVICES
DEPARTMENT

RECLAIMED WATER SYSTEM
REMOTE VALVE MODIFICATIONS

PLAN VIEW

SHEET
NO
1



REVISIONS			DESIGNED	JAM	 SEAHOLM COUNTY ENVIRONMENTAL SERVICES DEPARTMENT	RECLAIMED WATER SYSTEM REMOTE VALVE MODIFICATIONS	SECTION VIEW	SHEET
DATE	BY	DESCRIPTION	DRAWN	DMA				NO
			CHECKED	DGC				
			PREPARED	JAM				2